



SAFETY AND BUILDINGS DIVISION  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
**TTY: Contact Through Relay**

**Scott Walker, Governor**  
**Dave Ross, Secretary**

April 30, 2013

ECOLAB, INC.  
REGULATORY AFFAIRS  
JAMISON KORTAS  
370 N. WABASHA ST.  
ST. PAUL MN 55102-1390

Re: Description: PROPORTIONER  
Manufacturer: ECOLAB, INC.  
Product Name: OPTIPRO  
Model Number(s): SOLID ENZYMATIC DETERGENT DISPENSER, SOLID NEUTRAL DETERGENT  
DISPENSER AND SOLID ENZYMATIC MANUAL DISPENSER  
Product File No: 20130116

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.20 (5) (d) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2015.

This approval supersedes the approval issued on April 13, 2010 under product file number 20100142.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The tubing supplied with this product shall be listed for potable water use and have a temperature/ pressure rating of 180° F at 100 psig.
- These devices shall be installed with atmospheric vacuum breakers, which conform to ASSE 1001-2002, upstream of the water connection to each device.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
Plumbing Product Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
(608) 267-1401 Phone  
(608) 266-2602 Fax  
glen.schlueter@wi.gov E-mail